Appendix 25-1: Baseline Noise Monitoring Results














ORIEL WIND FARM PROJECT

Environmental Impact Assessment Report Appendix 25-1: Baseline Noise Monitoring Results



Contents

1	INTR	ODUCTI	ON	1
	1.1	Long te	rm noise monitoring	1
	1.2		ed noise monitoring sites	
	1.3	Prevaili	ng background noise curves and ETSU-R-97 Limits	0
2	BAS		OISE MONITORING	3
_	2.1		blogical data	
	2.2		ower fixed limit for daytime and night-time	
	2.3		and clustering of data for offshore vs onshore winds	
	2.4		ations at long term noise monitoring locations during deployment	
		2.4.1	NML1	
		2.4.2	NML2	4
		2.4.3	NML3	4
		2.4.4	NML4	4
		2.4.5	NML5	4
		2.4.6	NML6	5
		2.4.7	NML7	5
		2.4.8	NML8	5
		2.4.9	NML9	5
		2.4.10	NML10	5
	2.5		Durations and Issues Encountered	
	2.6		ing results at long term noise monitoring locations and derived noise limits	
		2.6.1	NML1	
		2.6.2	NML2	8
		2.6.3	NML3	-
		2.6.4	NML4	
		2.6.5	NML5	
		2.6.6	NML6	
		2.6.7	NML7	
		2.6.8	NML8	
		2.6.9	NML9	-
		2.6.10	NML10	
	2.7	Attende	ed noise monitoring results	21
3	SUM	MARY O	F BASELINE CURVES AND ETSU-R-97 LIMITS	23
4	PHO	TOGRAF	PHS OF MONITORING SITES	26
5	соо	RDINAT	ES OF MONITORING SITES	28
6	EQU	PMENT	CALIBRATION CERTIFICATES	29

Figures

Figure 1-1: Baseline Noise Monitoring Locations	2
Figure 1-2: Attended monitoring locations	0
Figure 2-1: Baseline Noise Levels – Daytime Amenity - NML1	7
Figure 2-2: Baseline Noise Levels – Night-time - NML1	7
Figure 2-3: Baseline Noise Levels – Daytime Amenity – NML2	8
Figure 2-4: Baseline Noise Levels – Night-time – NML2	9
Figure 2-5: Baseline Noise Levels – Daytime Amenity – NML3	10
Figure 2-6: Baseline Noise Levels – Night-time – NML3	10
Figure 2-7: Baseline Noise Levels – Daytime Amenity – NML4	11
Figure 2-8: Baseline Noise Levels – Night-time – NML4	12

ORIEL WIND FARM PROJECT – BASELINE NOISE MONITORING RESULTS

Figure 2-9: Baseline Noise Levels – Daytime Amenity – NML5	13
Figure 2-10: Baseline Noise Levels - Night-time - NML5	13
Figure 2-11: Baseline Noise Levels – Daytime Amenity – NML6	14
Figure 2-12: Baseline Noise Levels – Night-time – NML6	15
Figure 2-13: Baseline Noise Levels – Daytime Amenity – NML7	
Figure 2-14: Baseline Noise Levels – Night-time – NML7	
Figure 2-15: Baseline Noise Levels – Daytime Amenity – NML8	
Figure 2-16: Baseline Noise Levels – Night-time – NML8	
Figure 2-17: Baseline Noise Levels – Daytime Amenity – NML9	
Figure 2-18: Baseline Noise Levels – Night-time – NML9	
Figure 2-19: Baseline Noise Levels – Daytime Amenity – NML10	
Figure 2-20: Baseline Noise Levels – Night-time – NML10	

Tables

Table 2-1: Summary of survey locations, dates and overview of issues encountered	5
Table 2-2: Daytime/evening attended baseline noise measurements.	21
Table 2-3: Attended night-time baseline noise measurements at AML5	22
Table 3-1: Baseline and ETSU-R-97 Limit curves for NML1 and NML2 (Co. Down, NI)	23
Table 3-2: Baseline and ETSU-R-97 Limit curves for NML3, NML4 and NML5 (Cooley Peninsula)	23
Table 3-3: Baseline and ETSU-R-97 Limit curves for NML6 and NML7 (Blackrock and	
Castlebellingham, Co. Louth)	24
Table 3-4: Baseline and ETSU-R-97 Limit curves for NML8, NML9 and NML10 (Dunany Point and	
Clogher Head, Co. Louth).	24
Table 5-1: ITM coordinates of long term noise monitoring sites.	
Table 5-2: ITM coordinates of attended noise monitoring sites.	

1 INTRODUCTION

RPS was appointed by Oriel Windfarm Limited (OWL) to undertake baseline noise monitoring surveys to inform the noise impact assessment for the Oriel Wind Farm Project (hereinafter referred to as the Project), which is included in chapter 25: Noise and Vibration in the EIAR.

A comprehensive baseline noise monitoring campaign was carried out for the Project. This included long term noise monitoring at ten onshore locations (see section 1.1), which were chosen following a desktop study to examine the potential for operational wind turbine noise impacts at these locations. A further five locations were chosen for attended noise monitoring (see section 1.2) to examine potential noise impacts during the construction of the onshore cable and onshore substation site and also potential noise impacts from the operation of the onshore substation site.

1.1 Long term noise monitoring

A long-term baseline monitoring campaign was conducted at ten sites (NML1 – NML10) from 10th October 2022 to 25th November 2022. The monitoring sites include three sites on the coastline within 200 m of the high-water mark, six sites within approximately 1 km of the high-water mark, and one elevated site approximately 4 km inland on the Cooley Peninsula. The sites are spatially distributed along the coastline within the Noise and Vibration Study Area, as shown in Figure 1-1, and allow characterisation of the baseline environment for Noise Sensitive Locations (NSLs) which may potentially be impacted by Wind Turbine Noise (WTN) from the Project.


NSLs on the Cooley Peninsula have the shortest separation distance from the proposed Wind Turbine Generators (WTGs) within the Noise and Vibration Study Area (approximately 6 km distance between nearest WTG and nearest NSL). Three monitoring locations were therefore chosen on the Cooley Peninsula; one on the coast (NML5), two approximately 1 km (NML3) and 4 km (NML4) inland respectively. NML4 is at approximately 70 m altitude with direct line of sight to the site of proposed WTGs while being sufficiently inland for coastal noise to be significantly attenuated. Consequently, NML4 is representative of the most sensitive NSLs on the Cooley Peninsula, NML5 representative of the least sensitive NSLs (due to coastal noise) and NML3 between these two extremes, allowing characterisation of changes in the noise environment with distance from the coast.

Following those on the Cooley Peninsula, the next nearest NSLs are located on or near to Dunany Point. Similarly to the Cooley Peninsula noise monitoring strategy, two of the sites are located here, NML8 on the coastline and NML9 (approximately 1 km inland).

The remaining monitoring sites are spatially distributed along the coast within the Noise and Vibration Study Area as follows:

- NML1: approximately 150 m inland in Kilkeel, Co. Down;
- NML2: coastal location in Cranfield, Co. Down;
- NML6: approximately 280 m inland in Blackrock, Co. Louth;
- NML7: approximately 170 m inland in Castlebellingham, Co. Louth; and
- NML10: approximately 350 m inland in Clogherhead, Co. Louth.

Data from these ten sites forms an extensive and comprehensive dataset allowing assessment of the baseline noise environment for the range of locations within the Noise and Vibration Study Area. Monitoring at these locations was carried out in accordance with the Institute of Acoustics (IoA), Good Practice Guidelines (GPG) procedures to allow use of results to derive prevailing background noise curves for the setting of relative noise limits for WTN.



1.2 Attended noise monitoring sites

The attended monitoring sites (AML1 - AML5) are shown in Figure 1-2. The purpose of the attended survey was to characterise existing baseline conditions along the onshore cable route and at the nearest dwellings to the onshore substation site.

AML1 – AML4 are locations along the onshore cable route where it is possible for measurements to be conducted sufficiently distant from the road to be representative of baseline levels at the nearest NSL façades. AML5 was chosen as it provides an accessible location (i.e. similar distance and elevation with respect to the main ambient noise sources such as road traffic on the N33) which is representative of the baseline noise environment at the nearest NSLs to the onshore substation site.



Figure 1-2: Attended monitoring locations.

1.3 Prevailing background noise curves and ETSU-R-97 Limits

Monitoring durations at all long-term monitoring sites were sufficient to meet the data requirements of the IoA GPG and IoA GPG Supplementary Guidance Note 1 which specify recommended minimum numbers of data points within each windspeed bin. The noise monitoring results include a time series of 10-minute L_{A90} measurements at each site which are correlated with 10-minute average standardised 10-metre windspeeds (V10).

The datasets are used to produce scatter plot graphs with L_{A90,10min} values in dB plotted on the Y-axis against V10 windspeeds on the X-axis. The prevailing background noise curve is determined for the data by a least-squares regression formula. The daytime 'amenity' period is classified in the IoA GPG as:

- 18:00 23:00 every day;
- 13:00 18:00 Saturday; and
- 07:00 18:00 Sunday.

The night-time period is classified in ESTU-R-97 and the IoA GPG as:

• 23:00 – 07:00 every day.

Night-time data for analysis was restricted to 23:00 - 06:00 in order to avoid contributions of road traffic noise and the dawn chorus given the time of year.

Linear and polynomial trendlines are fitted to the data in accordance with ETSU-R-97 and with the coefficients of determination (R²) for each order of polynomial fit line determined for valid data. The "best fit" polynomial is determined as the curve that provides both a higher regression coefficient and a sensible visual match to the data. In accordance with the IoA GPG measurements affected by rain have been excluded. Additional exclusions of measurements showing evidence of extraneous noise have also been made as indicated.

ETSU-R-97 provides guidance regarding determination of the value for the lower fixed limit, stating that this should be done with consideration of the following three criteria:

- Number of dwellings in the neighbourhood of the wind farm.
 - "The more dwellings that are in the vicinity of a wind farm the tighter the limits should be as the total environmental impact will be greater. Conversely if only a few dwellings are affected, then the environmental impact is less and noise limits towards the upper end of the range may be appropriate."
- The effect of noise limits on the number of kWh generated.
 - "Similar arguments can be made when considering the effect of noise limits on uptake of wind energy. A single wind turbine causing noise levels of 40dB(A) at several nearby residences would have less planning merit (noise considerations only) than 30 wind turbines also causing the same amount of noise at several nearby residence."
- Duration and level of exposure.
 - "The proportion of the time at which background noise levels are low and how low the background noise level gets are both recognised as factors which could affect the setting of an appropriate lower limit. For example, a property which experienced background noise levels below 30dB(A) for a substantial proportion of the time in which the turbines would be operating could be expected to receive tighter noise limits than a property at which the background noise levels soon increased to levels above 35dB(A). This approach is difficult to formulate precisely and a degree of judgement should be exercised."

At many of the baseline monitoring locations the background noise levels are largely attributable to natural sources such as coastal noise rather than anthropogenic sources such as road traffic etc. Coastal noise varies with wind speed and direction, and also wave height and these conditions do not follow a diurnal pattern. Consequently, significant differences between daytime amenity and night-time prevailing background noise levels will not necessarily occur. ETSU-R-97 states the following regarding setting daytime and night-time limits:

"As the night-time lower fixed limit is greater than the day-time limit, the night-time limit could become superfluous unless background noise levels are less during the night than during the quiet day-time periods. Where the local authority and the developer are in agreement that the background noise levels do not vary significantly between the quiet day-time periods and the night-time, then a single lower fixed limit of 35-40dB(A) can be imposed based upon background noise levels taken during quiet day-time periods and the night analysed together."

Paragraph 3.2.9 of the IoA GPG states the following regarding the above:

"There is no definition of what is considered significant in this context, but where the amenity and night-time derived background noise levels differ by the order of 3 dB or less, over the key wind speed range between cut-in to when the turbines reaches their maximum level of noise emissions, it could then be appropriate to apply this clause of ETSU-R-97."

Given the above, it is considered appropriate to set a single daytime and night-time lower fixed noise limit where the above conditions have been satisfied in data measured at the monitoring sites. In the case that a single lower fixed limit is imposed, it is important that this limit is "based upon background noise levels taken during quiet day-time periods and the night analysed together" as well as consideration of the three criteria referenced above.

2 BASELINE NOISE MONITORING

2.1 Meteorological data

Meteorological data for the survey was supplied from a Lidar unit deployed near to NML8. The hub heights of proposed WTGs range from 145 – 152 m and the Lidar data included measurement of windspeed and direction at 123 m and 163 m. For conservative derivation of prevailing background noise curves, the 152 m hub height is assumed and the average hub height 10-minute windspeeds (VHH) have been calculated from the 123 m and 163 m measurements using equations 2 and 3 from the IoA GPG Supplementary Guidance Note 4. As recommended by the IoA GPG, average wind direction from the nearest measurement height, 163 m, has been used directly. Finally V10 windspeeds have been calculated using a roughness length of 0.05 m as specified by the IoA GPG.

Measurements from the onshore Lidar unit located close to NML8 have been compared with measurements from a floating Lidar which was deployed within the bounds of the site of the proposed WTGs, with excellent correlation shown. The floating Lidar was no longer in position at the time of the baseline monitoring and therefore measurements from the onshore Lidar have been used for baseline analysis.

2.2 Single lower fixed limit for daytime and night-time

Seven of the ten long term monitoring sites analysed meet the condition for setting a single lower fixed limit for both the daytime and the night-time (i.e. the background noise levels do not vary significantly between the quiet day-time periods and the night-time). Therefore, rather than separate lower fixed limits for the daytime amenity and night-time periods, the assessment will be conducted using a single lower fixed limit for the daytime amenity and night-time periods at all sites based on the daytime amenity and night-time background levels analysed together.

The ETSU-R-97 three criteria are described in section 1 and provide guidance for the determination of the lower fixed limit. Additional guidance regarding the three criteria is provided in the IoA GPG. Commentary on the three criteria in relation to the Project is given below:

- Number of dwellings in the neighbourhood of the wind farm:
 - The IoA GPG suggests the predicted 35 dB WTN contour should be used to define the neighbourhood of the wind farm.
 - There are no noise sensitive locations located within the 35 dB WTN contour.
 - The generating capacity of the Project indicates the potential to supply electricity for approximately 300,000 homes.
 - Given there are no NSLs in the neighbourhood of the Project, a 40 dB lower fixed limit would be indicated by the first criterion.
- The effect of noise limits on the number of kWh generated:
 - The generating capacity of the Project is 375MW and the fixed lower limit has no impact on the generating capacity suggesting that a reduced lower limit in the range 35 – 40 dB may be applied.
- Duration and level of exposure:
 - The prevailing wind direction places NSLs upwind of WTGs for most of the year and the predicted noise levels are low compared to the measured background levels, indicating that the likely duration and level of exposure is low indicating that a lower fixed limit toward the upper end of the range of 35 - 40 dB allowed could be justified.

There is no particular detail offered within ETSU-R-97 or the IoA GPG as to how the how the daytime amenity and night-time levels should be analysed together. Given the night-time lower fixed limit would otherwise be 43dB L_{A90,10min}, a single lower fixed limit for both daytime and night-time which is lower than

43dB should not result in significantly lower limits during the daytime than would result from the daytime amenity levels analysed alone.

Having given due consideration to the factors listed above, a fixed lower limit of 37.5dB L_{A90,10min} is recommended for both the daytime amenity and night-time periods at all NSLs within the Noise and Vibration Study Area.

2.3 Spread and clustering of data for offshore vs onshore winds

For the coastal monitoring sites, significant differences have been observed between noise levels measured during offshore and onshore wind directions. The plots exhibit clustering of the offshore and onshore data, particularly at higher windspeeds. There is also a very wide spread in data for some windspeeds at certain locations due to low noise levels measured when the winds are directly offshore and sites are sheltered by topography vs the onshore direction with surf and wave noise.

The wind directions placing receivers downwind of WTGs are onshore and therefore exclusion of direct offshore winds could be justified. The effect of including monitoring results during offshore wind conditions is to lower the derived noise limits somewhat. In the context of this assessment, which includes inshore monitoring locations which are more sensitive, the effect of including the offshore results in analysis for coastal sites is considered to be minimal and therefore directional filtering of monitoring results is not applied.

2.4 Observations at long term noise monitoring locations during deployment

2.4.1 NML1

At NML1, the monitoring equipment was installed in the back garden of the property approximately 2 m from the rear wall of the garden due to the limited space available. The primary noise source observed during installation was the rustling of vegetation from surrounding garden plants. Other noise sources included occasional local road traffic noise and distant road traffic noise.

2.4.2 NML2

At NML2, the monitoring equipment was installed in the back garden of the property approximately 3.5 m from the rear wall of the building. This location is in close proximity to the nearby beach and the dominant noise source was waves breaking on the shore. Occasional local road traffic noise was also present.

2.4.3 NML3

At NML3, the monitoring equipment was installed in the back garden of the property approximately 3.5 m from the rear wall of the garden and approximately 7 m from a large shed. The shed is used for storage only and no activity takes place within it. There is a well nearby which fills with rainwater but is otherwise unused. Power lines are present approximately 25 m south of the equipment. It is a quiet location, with light birdsong and distant road traffic noise being the only audible sounds during installation.

2.4.4 NML4

At NML4, the monitoring equipment was installed approximately 6 m in front of the property. This location is situated on a slope, slightly elevating NML4 in comparison to the land immediately in front of the property. There is a large tree approximately 13 m from NML4 in a neighbouring garden which was sparsely leaved at the time of installation. A quiet road runs in front of the property and very occasional local road traffic noise was observed. Across the road from NML4 is a field containing a small number of sheep. Other noise sources included gentle birdsong and the slight rustling of surrounding vegetation.

2.4.5 NML5

At NML5, the monitoring equipment was mounted on a wooden fence below the nearby caravan park. The equipment was in close proximity to the beach below and the dominant noise source observed was waves

breaking on the shore. Other noise sources included birdsong and occasional noise from workers at the caravan park.

2.4.6 NML6

At NML6, the monitoring equipment was installed in the back garden of the property approximately 2 m from the rear wall of the garden. The garden contains a significant amount of vegetation and the dominant noise source observed during installation was vegetation rustle. This property is located within a residential estate and the sounds of children playing, distant dog barking and distant road traffic noise could be heard.

2.4.7 NML7

At NML7, the monitoring equipment was installed in the back garden of the property approximately 3.5 m from the rear wall of the building. The dominant noise source observed was the rustling of a large tree in the corner of the garden. A boiler flue is located towards the opposite side of the garden near the shed but was not in operation at the time of installation. The monitoring equipment was set up approximately 7 m from the large tree, leaving it closer to the tree than the boiler flue. Light birdsong, distant dog barking and distant road traffic noise were also present at this location.

2.4.8 NML8

At NML8, the monitoring equipment was installed at the edge of the landowner's field in the overgrowth with the nearest NSL situated approximately 50 m away. This location was chosen as the landowner intended to plough the field during the following week. The dominant noise source observed was the breaking of waves on the shore below. The location is quite exposed to wind which resulted in the rustling of surrounding vegetation. Birdsong was present and the distant sound of a chainsaw could be heard from a neighbouring property. Occasional road traffic noise from the road below the location was also observed.

2.4.9 NML9

At NML9, the monitoring equipment was installed in the corner of a field within a small cul-de-sac approximately 60 m from the nearest NSL. A small number of sheep were present on the land directly in front of this property. The road running perpendicular to the cul-de-sac is quiet and only distant road traffic noise was observed. Some rustling from a large tree approximately 13 m from the equipment could be heard along with gentle birdsong. During installation, an aircraft passed overhead.

2.4.10 NML10

At NML10, the monitoring equipment was mounted on a wooden fence in the back yard of the property. The field to the rear of this location contains livestock. Due to the absence of vegetation and the presence of hard wall and ground surfaces, the back yard presents an acoustically reflective environment. There is a quiet road in front of the property which gave rise to intermittent road traffic noise. Other noise sources observed were birdsong and distant dog barking. Lawnmowing at a neighbouring property prevented the identification of any other noise sources during installation.

2.5 Survey Durations and Issues Encountered

The dates of surveys and a summary of issues encountered with equipment during the survey period is provided in Table 2-1. Issues encountered included insufficient charge current from solar panels due to shading, SD card failure, damage to one monitor, and a lightning strike to the Lidar meteorological monitoring unit.

Table 2-1: Summary of survey	v locations, dates and overview of issues encountered.
------------------------------	--

Site	Location	Start Date End Date	Overview of Survey / Issues
NML1	Kilkeel	13/10/2022 18/11/202	2 Tight back garden solar charge difficulties. Additional solar capacity added. Offline from 19/10/22 to 21/10/22
NML2	Cranfield	13/10/2022 18/11/202	2 Continuous noise monitoring – no issues
NML3	Ballagan	10/10/2022 18/11/202	2 Continuous noise monitoring – no issues

ORIEL WIND FARM PROJECT – BASELINE NOISE MONITORING RESULTS

Site	Location	Start Date	End Date	Overview of Survey / Issues
	Rain Gauge	10/10/2022	18/11/2022	Continuous rain monitoring – no issues
NML4	The Grange	10/10/2022	18/11/2022	Continuous noise monitoring – no issues
NML5	Gyles Quay	14/10/2022	18/11/2022	Continuous noise monitoring – no issues
NML6	Blackrock	13/10/2022	18/11/2022	SD card failure. Data from 21/10/22 to 28/10/22 missing. Replaced card on 28/10/22
NML7	Castlebellingham	10/10/2022	18/11/2022	Continuous noise monitoring – no issues
	Rain Gauge	10/10/2022	18/11/2022	Continuous rain monitoring – no issues
NML8	Dunany (Landfall)	10/10/2022	25/11/2022	Solar panel issues. Offline from 15/10/22 to 24/10/22 Worked following replacement on 24/10/22
	Lidar	10/10/2022	25/11/2022	Monitoring of wind speed and direction. Lidar unit was offline from 10/10/22 to 25/10/22 following lightning strike.
NML9	Dunany (~1 km inland)	28/10/2022	25/11/2022	Equipment damaged, removed on 21/10/22. Reinstalled on 28/10/22
	Rain Gauge	18/11/2022	25/11/2022	Continuous rain monitoring – no issues
NML10	Clogherhead	10/10/2022	18/11/2022	Continuous noise monitoring – no issues
	Rain Gauge	10/10/2022	18/11/2022	Continuous rain monitoring – no issues

2.6 Monitoring results at long term noise monitoring locations and derived noise limits

Scatter plots, derivation of prevailing background trendlines, and derivation of ETSU-R-97 noise limits have been conducted for each of the long term noise monitoring sites. Graphs for daytime and night-time at each site are shown in the following subsections. While the graphs show monitoring results up to a wind speed of 12 m/s, the regression analysis has included all valid measured data up to approximately 18 m/s.

2.6.1 NML1

Figure 2-1 and Figure 2-2 show the data measured at NML1 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-1: Baseline Noise Levels – Daytime Amenity - NML1.




Figure 2-2: Baseline Noise Levels – Night-time - NML1.

MDR1520B | EIAR – Appendix 25-1 | F01 | August 2023 rpsgroup.com

2.6.2 NML2

Figure 2-3 and Figure 2-4 show the data measured at NML2 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-3: Baseline Noise Levels – Daytime Amenity – NML2.




Figure 2-4: Baseline Noise Levels – Night-time – NML2.

2.6.3 NML3

Figure 2-5 and Figure 2-6 show the data measured at NML3 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-5: Baseline Noise Levels – Daytime Amenity – NML3.




Figure 2-6: Baseline Noise Levels – Night-time – NML3.

MDR1520B | EIAR – Appendix 25-1 | F01 | August 2023 rpsgroup.com

2.6.4 NML4

Figure 2-7 and Figure 2-8 show the data measured at NML4 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-7: Baseline Noise Levels – Daytime Amenity – NML4.




Figure 2-8: Baseline Noise Levels – Night-time – NML4.

2.6.5 NML5

Figure 2-9 and Figure 2-10 show the data measured at NML5 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-9: Baseline Noise Levels – Daytime Amenity – NML5.




Figure 2-10: Baseline Noise Levels – Night-time – NML5.

2.6.6 NML6

Figure 2-11 and Figure 2-12 show the data measured at NML6 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-11: Baseline Noise Levels – Daytime Amenity – NML6.




Figure 2-12: Baseline Noise Levels – Night-time – NML6.

2.6.7 NML7

Figure 2-13 and Figure 2-14 show the data measured at NML7 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-13: Baseline Noise Levels – Daytime Amenity – NML7.




Figure 2-14: Baseline Noise Levels – Night-time – NML7.

2.6.8 NML8

Figure 2-15 and Figure 2-16 show the data measured at NML8 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-15: Baseline Noise Levels – Daytime Amenity – NML8.




Figure 2-16: Baseline Noise Levels – Night-time – NML8.

2.6.9 NML9

Figure 2-17 and Figure 2-18 show the data measured at NML9 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-17: Baseline Noise Levels – Daytime Amenity – NML9.




Figure 2-18: Baseline Noise Levels – Night-time – NML9.

MDR1520B | EIAR – Appendix 25-1 | F01 | August 2023 rpsgroup.com

2.6.10 NML10

Figure 2-19 and Figure 2-20 show the data measured at NML10 during the baseline noise monitoring for the daytime amenity and night-time periods respectively.




Figure 2-19: Baseline Noise Levels – Daytime Amenity – NML10.




Figure 2-20: Baseline Noise Levels – Night-time – NML10.

2.7 Attended noise monitoring results

The attended noise survey was conducted from 15:00 on 28 February 2023 to 01:00 on 1 March 2023. Three 15-minute daytime measurements were conducted at AML1 to AML4 to inform the BS 5228 construction noise assessment. Two 15-minute night-time measurements were conducted at AML5 to inform the onshore substation operational noise assessment.

Table 2-2 summarises the daytime and evening measurements conducted at the five attended monitoring locations.

Site	Start date/time	Duration	Measured b	BS 5228		
			L _{Aeq} (energy average)	L _{AFmax} (max)	L _{A90} (average)	ABC Category
AML1	28/02/2023 15:21	3 x 15min	52	76	40	А
AML2	28/02/2023 16:34	3 x 15min	50	72	39	А
AML3	28/02/2023 17:43	3 x 15min	51	68	42	А
AML4	28/02/2023 18:59	3 x 15min	69	89	51	В

Table 2-3 summarises the night-time measurements conducted at AML5.

Start date/time	Duration	Measur (dB)	ed broadba	nd levels	1/3 octave L _{Aeq} (dB) for centre frequency (Hz)			
		L _{Aeq}		L _{A90}	100 Hz	200 Hz	315 Hz	
01/03/2023 00:06	00:15:00	45	57	31	12	15	22	
01/03/2023 00:22	00:15:00	45	61	31	12	17	23	

Table 2-3: Attended night-time baseline noise measurements at AML5.

3 SUMMARY OF BASELINE CURVES AND ETSU-R-97 LIMITS

As expected, the monitoring results show a large difference in baseline levels measured at coastal vs inland sites. Table 3-1 shows results and limits for the following two monitoring sites in Co. Down, Northern Ireland with the influence of coastal noise shown in results from both sites:

- NML1 approximately 150 m inland, sheltered rear garden; and
- NML2 Coastal, exposed garden location.

Table 3-1: Baseline and ETSU-R-97 Limit curves for NML1 and NML2 (Co. Down, NI).

Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML1	Daytime Amenity Curve (dB L _{A90})	32.6	33.2	34.0	35.1	36.5	38.0	39.6	41.4	43.2
	Daytime Limit (dB L _{A90})	37.6	38.2	39.0	40.1	41.5	43.0	44.6	46.4	48.2
	Night-time Curve (dB L _{A90})	31.6	32.1	32.6	33.4	34.2	35.3	36.5	37.9	39.5
	Night-time Limit (dB L _{A90})	37.5	37.5	37.6	38.4	39.2	40.3	41.5	42.9	44.5
Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML2	Daytime Amenity Curve (dB L _{A90})	42.1	43.7	45.4	47.1	48.7	50.3	51.9	53.3	54.7
	Daytime Limit (dB L _{A90})	47.1	48.7	50.4	52.1	53.7	55.3	56.9	58.3	59.7
	Night-time Curve (dB L _{A90})	41.7	43.6	45.3	47.0	48.7	50.3	51.8	53.3	54.7
	Night-time Limit (dB L _{A90})	46.7	48.6	50.3	52.0	53.7	55.3	56.8	58.3	59.7

Relatively high baseline levels were recorded for NML5 on the coast. The lowest baseline levels were measured at NML3 which is located approximately 1 km inland. Table 3-2 shows results for the following three sites located on the Cooley Peninsula.

- NML3 approximately 1 km inland, exposed garden location;
- NML4 approximately 4 km inland, exposed garden location; and
- NML5 coastal, exposed deck location overlooking beach.

Table 3-2: Baseline and ETSU-R-97 Limit curves for NML3, NML4 and NML5 (Cooley Peninsula).

Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML3	Daytime Amenity Curve (dB LA90)	27.5	27.9	28.7	29.8	31.1	32.6	34.3	36.2	38.2
	Daytime Limit (dB LA90)	37.5	37.5	37.5	37.5	37.5	37.6	39.3	41.2	43.2
	Night-time Curve (dB LA90)	26.5	27.3	28.3	29.4	30.6	32.0	33.6	35.3	37.2
	Night-time Limit (dB LA90)	37.5	37.5	37.5	37.5	37.5	37.5	38.6	40.3	42.2
Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML4	Daytime Amenity Curve (dB LA90)	31.8	33.1	34.3	35.4	36.3	37.3	38.3	39.4	40.6

ORIEL WIND FARM PROJECT – BASELINE NOISE MONITORING RESULTS

Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
	Daytime Limit (dB LA90)	37.5	38.1	39.3	40.4	41.3	42.3	43.3	44.4	45.6
	Night-time Curve (dB LA90)	28.0	28.2	28.6	29.2	30.0	31.0	32.3	33.8	35.5
	Night-time Limit (dB LA90)	37.5	37.5	37.5	37.5	37.5	37.5	37.5	38.8	40.5
Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML5	Daytime Amenity Curve (dB LA90)	47.4	49.2	50.9	52.6	54.2	55.7	57.2	58.6	59.9
	Daytime Limit (dB L _{A90})	52.4	54.2	55.9	57.6	59.2	60.7	62.2	63.6	64.9
	Night-time Curve (dB LA90)	49.0	50.4	51.8	53.2	54.5	55.9	57.2	58.5	59.8
	Night-time Limit (dB LA90)	54.0	55.4	56.8	58.2	59.5	60.9	62.2	63.5	64.8

Table 3-3 shows results for the following sites closest to Dundalk town:

- NML6 approximately 300m inland, sheltered garden location; and
- NML7 approximately 170m inland, somewhat sheltered location.

Table 3-3: Baseline and ETSU-R-97 Limit curves for NML6 and NML7 (Blackrock and Castlebellingham, Co. Louth).

Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML6	Daytime Amenity Curve (dB LA90)	35.6	35.6	35.6	35.5	35.7	36.2	37.0	38.1	39.4
	Daytime Limit (dB LA90)	40.6	40.6	40.6	40.5	40.7	41.2	42.0	43.1	44.4
	Night-time Curve (dB LA90)	32.2	31.8	31.7	31.9	32.4	33.1	34.1	35.4	36.9
	Night-time Limit (dB LA90)	37.5	37.5	37.5	37.5	37.5	38.1	39.1	40.4	41.9
Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML7	Daytime Amenity Curve (dB L _{A90})	34.5	34.9	35.3	35.9	36.6	37.5	38.6	40.0	41.6
		54.5	54.5	55.5	35.9	30.0	57.5	50.0	40.0	4 1.0
	Daytime Limit (dB LA90)	39.5	39.9	40.3	40.9	41.6	42.5	43.6	45.0	46.6
										-

Table 3-4 shows results for the following three southern-most monitoring sites:

- NML8 coastal, exposed location in field;
- NML9 approximately 1 km inland, exposed location in field; and
- NML10 approximately 350 m inland, exposed location.

Table 3-4: Baseline and ETSU-R-97 Limit curves for NML8, NML9 and NML10 (Dunany Point and Clogher Head, Co. Louth).

Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML8	Daytime Amenity Curve (dB L _{A90})	44.0	44.3	44.8	45.5	46.4	47.4	48.7	50.1	51.8
	Daytime Limit (dB L _{A90})	49.0	49.3	49.8	50.5	51.4	52.4	53.7	55.1	56.8
	Night-time Curve (dB L _{A90})	43.3	43.6	44.2	44.9	45.7	46.8	48.0	49.4	51.0
	Night-time Limit (dB L _{A90})	48.3	48.6	49.2	49.9	50.7	51.8	53.0	54.4	56.0

ORIEL WIND FARM PROJECT – BASELINE NOISE MONITORING RESULTS

Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML9	Daytime Amenity Curve (dB L _{A90})	28.7	29.2	30.0	31.1	32.4	34.1	36.0	38.1	40.5
	Daytime Limit (dB L _{A90})	37.5	37.5	37.5	37.5	37.5	39.1	41.0	43.1	45.5
	Night-time Curve (dB L _{A90})	28.2	28.2	28.6	29.4	30.5	32.0	33.8	36.0	38.5
	Night-time Limit (dB L _{A90})	37.5	37.5	37.5	37.5	37.5	37.5	38.8	41.0	43.5
Site	V10 (m/s)	2	3	4	5	6	7	8	9	10
NML10	Daytime Amenity Curve (dB L _{A90})	36.1	36.8	37.7	38.6	39.6	40.7	41.9	43.2	44.7
	Daytime Limit (dB L _{A90})	41.1	41.8	42.7	43.6	44.6	45.7	46.9	48.2	49.7
	Night-time Curve (dB L _{A90})	35.9	36.5	37.2	38.0	39.0	40.1	41.3	42.7	44.2
	Night-time Limit (dB L _{A90})	40.9	41.5	42.2	43.0	44.0	45.1	46.3	47.7	49.2

4 PHOTOGRAPHS OF MONITORING SITES

Photographs of the noise monitoring equipment deployed at each of the ten monitoring sites are displayed in below.



NML1

NML2



NML3

NML4

NML9

NML10

Page 27



NML7

NML8



NML5

NML6



5 COORDINATES OF MONITORING SITES

Table 5-1 details the Irish Transverse Mercator (ITM) coordinates for each of the ten long-term monitoring sites.

Table 5-1: ITM coordinates of long term noise monitoring sites.

Site	Easting (ITM)	Northing (ITM)	
NML1	730793	813714	
NML2	727744	810678	
NML3	722828	807463	
NML4	718796	808469	
NML5	715140	805688	
NML6	707158	803216	
NML7	706869	796684	
NML8	715326	790971	
NML9	714237	791033	
NML10	716303	783961	

Table 5-2 details the Irish Transverse Mercator (ITM) coordinates for each of the five attended monitoring sites.

Table 5-2: ITM coordinates of attended noise monitoring sites.

Site	Easting (ITM)	Northing (ITM)
AML1	714473	789759
AML2	711069	789061
AML3	706516	791132
AML4	703699	791078
AML5	698444	790362

6 EQUIPMENT CALIBRATION CERTIFICATES

Brüel & Kja	er 🛯 🧰 🖷		- non	DALLAL
The Calibration Laboratory Skodsborgvej 307, DK-2850 Næ	rum, Denmark			CAL Reg.nr. 307
CERTIFICATE	E OF CALIBRATION	No: CDK22	08920	Page 1 of 12
CALIBRATION	OF			
Sound Level Meter: Microphone: Preamplifier: Supplied Calibrator:	Brüel & Kjær Type 2250 Brüel & Kjær Type 4950 Brüel & Kjær Type ZC-0032 Brüel & Kjær Type 4231	No: 2654662 No: 2730389 No: 6822 No: 2626210	Id: - 2654662	
Software version: Instruction manual:	BZ7222 Version 4.7.5 BE1712-22	Pattern Approval:	PTB1.63-40473 4078502	3500 / 1.63-
CUSTOMER				
	Unit 2A, Century Business F Dublin D11 T0HV Ireland	Park		
CALIBRATION	CONDITIONS			
CALIBRATION Preconditioning: Environment conditions:	4 hours at $23^{\circ}C \pm 3^{\circ}C$	ntal conditions sections.		
Preconditioning: Environment conditions:	4 hours at 23°C ± 3°C See actual values in Environmen	ntal conditions sections.		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1	4 hours at 23°C ± 3°C See actual values in Environmen	alibrated in accordance with t		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of	4 hours at 23°C ± 3°C See actual values in Environmen NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20	alibrated in accordance with t		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have	4 hours at 23°C ± 3°C See actual values in Environmen NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level	odic tests. The ac Meter Calibratio	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type	4 hours at $23^{\circ}C \pm 3^{\circ}C$ See actual values in Environment VS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:200 of the international units system SI.	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level	odic tests. The ac Meter Calibratio	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi	4 hours at $23^{\circ}C \pm 3^{\circ}C$ See actual values in Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u pration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalue in the standards, calibration method,	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in ac	odic tests. The ac Meter Calibratio 50, 4189 (IEC616 verage factor $k = 2$ ccordance with E/	n System 3630 with 72:2013)
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from from the device under ca	4 hours at $23^{\circ}C \pm 3^{\circ}C$ See actual values in Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u pration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalue in the standards, calibration method,	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in a effect of environmental condi	odic tests. The ac Meter Calibratio 50, 4189 (IEC616 verage factor $k = 2$ ccordance with E/	n System 3630 with 72:2013)

Brüel & Kja The Calibration Laboratory Skodsborgvej 3 7, DK-2850 Næ		AC-MRA	CAL Reg.nr. 307
CERTIFICATE	COF CALIBRATION	No: CDK2205023	Page 1 of 10
CALIBRATION Calibrator 1/2 inch adaptor	OF Brüel & Kjær Type 4231 Brüel & Kjær Type UC0210	No: 2292707	
Pattern Approval:	PTB-1.61-4057176		
CUSTOMER	Enfonic Ltd Unit 2A Century Business Park D11 T0HV Dublin Ireland		
	4 hours at 23°C ± 3°C See actual values in Environmental con	ance with the requirements as specified	
	een performed with the assistance of Bruel & on 2.4) by using procedure P 4231 D04.	Kjaer acoustic calibrator calibration ap	plication
RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi	ration as received. ncertainty is based on the standard uncertai mately 95 %. The uncertainty evaluation ha n the standards, calibration method, effect o	as been carried out in accordance with	EA-4/02 from
	on: 2022-08-18	Date of issue: 2022-08-	18
Date of calibrat			

Brüel & Kja		S. H.	111. +	
The Calibration Laboratory		ilac-	RA 🖤	DANAK
Skodsborgvej 307, DK-2850 Na	rrum, Denmark	"Hulphalan	white	CAL Reg.nr. 307
CERTIFICATE	E OF CALIBRATION	No: CDK21	04736	Page 1 of 12
CALIBRATION	OF			
Sound Level Meter:	Brüel & Kjær Type 2250	No: 3001350	Id: -	
Microphone:	Brüel & Kjær Type 4189	No: 3022867		
Preamplifier: Supplied Calibrator:	Brüel & Kjær Type ZC-0032 None	No: 23775		
Software version:	BZ7222 Version 4.5.2	Detterm Assures la	DTD1 (2 4047)	8500 / 1 / 2
Instruction manual:	BE1712-22 BE1712-22	Pattern Approval:	PTB1.63-4047 4078502	830071.63-
CUSTOMER				
	Enfonic Ltd			
	Unit 2A, Century Business F Dublin	Park		
	D11 T0HV			
	Ireland			
CALIBRATION	CONDITIONS			
Preconditioning:	4 hours at $23^{\circ}C \pm 3^{\circ}C$			
Preconditioning:	4 hours at $23^{\circ}C \pm 3^{\circ}C$	ntal conditions sections.		
Preconditioning: Environment conditions:	4 hours at 23°C ± 3°C See actual values in Environmen	ntal conditions sections.		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1	4 hours at 23°C ± 3°C See actual values in Environmen	alibrated in accordance with t		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of	4 hours at 23°C ± 3°C See actual values in Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20	alibrated in accordance with t		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have	4 hours at 23°C ± 3°C See actual values in Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level	odic tests. The ac Meter Calibratio	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software typ	4 hours at 23°C ± 3°C <i>See actual values in</i> Environmen NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level	odic tests. The ac Meter Calibratio	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software typ RESULTS	4 hours at 23°C ± 3°C 5 <i>See actual values in</i> Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20. of the international units system S1. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level	odic tests. The ac Meter Calibratio	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software typ RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from	4 hours at 23°C ± 3°C <i>See actual values in</i> Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u pration as received. uncertainty is based on the standard u mately 95 %. The uncertainty evalue in the standards, calibration method,	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov	odic tests. The ac Meter Calibratio 50, 4189 (IEC616 verage factor $k = 2$ ccordance with E/	n System 3630 with 72:2013) 2 providing a level A-4/02 from
IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software typ RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from from the device under ca	4 hours at 23°C ± 3°C <i>See actual values in</i> Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u pration as received. uncertainty is based on the standard u mately 95 %. The uncertainty evalue in the standards, calibration method,	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condi	odic tests. The ac Meter Calibratio 50, 4189 (IEC616 verage factor $k = 2$ ccordance with E/	n System 3630 with 72:2013) 2 providing a level A-4/02 from
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software typ RESULTS Calibration Mode: Calibr The reported expanded u of confidence of approxi- elements originating from from the device under ca	4 hours at 23°C ± 3°C See actual values in Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system S1. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u pration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalua n the standards, calibration method, dibration.	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condi	odic tests. The ac Meter Calibratio 50, 4189 (IEC616 verage factor $k = 2$ coordance with EA tions and any sho	n System 3630 with 72:2013) 2 providing a level A-4/02 from
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software typ RESULTS Calibration Mode: Calibr The reported expanded u of confidence of approxi elements originating from from the device under ca	4 hours at 23°C ± 3°C See actual values in Environment NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system S1. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u pration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalua n the standards, calibration method, dibration.	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condi	odic tests. The ac Meter Calibratio 50, 4189 (IEC616 verage factor $k = 2$ coordance with EA tions and any sho	n System 3630 with 72:2013) 2 providing a level A-4/02 from rt time contribution

Brüel & Kja The Calibration Laboratory Skodsborgvej 307, DK-2850 Nær				DANAK CAL Reg.nr. 307
CERTIFICATE	COF CALIBRATION	No: CDK22	202900	Page 1 of 12
CALIBRATION	OF			
Sound Level Meter:	Brüel & Kjær Type 2250	No: 3002365	Id: - 3002365	
Microphone:	Brüel & Kjær Type 4950	No: 2807020		
Preamplifier: Supplied Calibrator:	Brüel & Kjær Type ZC-0032 None	No: 15085		
Software version: Instruction manual:	BZ7222 Version 4.7.5 BE1712-22	Pattern Approval:	PTB1.63-4047 4078502	8500 / 1.63-
CUSTOMER				
	Enfonic Ltd Unit 2A, Century Business I Dublin D11 T0HV	Park		
	Ireland			
CALIBRATION Preconditioning:	Ireland CONDITIONS 4 hours at $23^{\circ}C \pm 3^{\circ}C$	ntal conditions sections		
Preconditioning: Environment conditions:	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme	ntal conditions sections.		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1.	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme	alibrated in accordance with		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1. assures the traceability of	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme JS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20	alibrated in accordance with		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1. assures the traceability of PROCEDURE The measurements have	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme JS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20	alibrated in accordance with 13 were used perform the perf of Brüel & Kjær Sound Level	iodic tests. The ac	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1, assures the traceability of PROCEDURE The measurements have application software type	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme NS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance	alibrated in accordance with 13 were used perform the perf of Brüel & Kjær Sound Level	iodic tests. The ac	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1. assures the traceability of PROCEDURE The measurements have application software type RESULTS	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme JS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u	alibrated in accordance with 13 were used perform the perf of Brüel & Kjær Sound Level	iodic tests. The ac	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1. assures the traccability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi-	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme JS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u ration as received. ncertainty is based on the standard u mately 95 %. The uncertainty evalue n the standards, calibration method,	alibrated in accordance with 13 were used perform the peri of Brüel & Kjær Sound Leve Ising procedure B&K proc 22 uncertainty multiplied by a cor ation has been carried out in a	 iodic tests. The ac 1 Meter Calibratio 50, 4189 (IEC616 verage factor k = 2 verage factor k = 2 	n System 3630 with (72:2013) 2 providing a level A-4/02 from
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1. assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxim	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme VS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance the international units system SI. Solutional	alibrated in accordance with 13 were used perform the perf of Brüel & Kjær Sound Level using procedure B&K proc 22 uncertainty multiplied by a cor ation has been carried out in a effect of environmental condi	 iodic tests. The ac 1 Meter Calibratio 50, 4189 (IEC616 verage factor k = 2 verage factor k = 2 	n System 3630 with (72:2013) 2 providing a level A-4/02 from
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1. assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxin elements originating from from the device under ca	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme VS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance the international units system SI. Solutional	alibrated in accordance with 13 were used perform the perf of Brüel & Kjær Sound Level using procedure B&K proc 22 uncertainty multiplied by a cor ation has been carried out in a effect of environmental condi	iodic tests. The ac 1 Meter Calibratio 50, 4189 (IEC616 verage factor $k = 2$ recordance with E. itions and any sho	n System 3630 with (72:2013) 2 providing a level A-4/02 from

Issued by University of	salford (Acoustics Calibration CALIBRATION LABORATO	n Laboratory)			
Page 1 of 3					\mathbf{O}
APPROVED SIG	NATORIES				U K A S CALIBRATION
Claire Lomax [x]	Sean Furlong[]	6			0801
Gary Phillips []	Danny McCaul []	C). (a.		
	alibration lab	oratory	17		University of Salford
The University of Salford,	Salford, Greater Manchester, MS	AWT, UK	y		
http://www.acoustics.s			a e sule		MANCHESTER
	vibilitio E L				
0	05050/0		D 1	61 OF M	1 0000
Certificate NL	imber: 05659/2		Date	of Issue: 25 Ma	rch 2022
PERIODI	C TEST OF A SC	OUND LE	VEL MET	ER to IEC 6167	2-3:2006
	FOR:	Enfonic La Unit 2 A	td		
			usiness Park		
		Dublin	2		
		D11 TOHV	P		
FOR	THE ATTENTION OF:	Bruna Bar	ros		
	DATE RECEIVED:	16 March	2022		
P	ERIODIC TEST DATE:	18 th and 21	l st March 2022		
LOCATIO	ON OF CALIBRATION:	Accustic	"alibration I ab	oratory, Newton G31,	I Inimoraity of Cold
LOCATIC	IN OF CALIBITATION.	Acousae e		oratory, Newton 651,	Oniversity of San
	TEST PROCEDURE:	CTP12 (L	aboratory Manı	lal)	
Sound Level Meter		<u></u>			
	Manufacturer	B&K			
	Model	2250 L			
	Serial number	3002367			
	Class	1			
	Hardware version: 4.0	Software B	Z7133 Version	4.7.5	
Associated Items:-			<i></i>		15
Туре	Manufacturer		Model	Serial Number	Adaptor
Microphone	B&K B&V		4950	2745852	
Preamplifier Calibrator	B&K B&K		ZC 0032 4231	16743 2343370	UC 0210
	- DOOL		1001		1000210

institutes. This certificate may not be reproduced other than in full except with the prior written approval of the issuing laboratory.

Certificate of Calibration

Issued by University of Salford (Acoustics Calibration Laboratory) UKAS ACCREDITED CALIBRATION LABORATORY NO. 0801

Page 2 of 3

Certificate Number: 05659/2

Date of Issue: 25 March 2022

Procedures from IEC 61672-3: 2006 and TPS 49 Edition 2 June 2009 were used to perform the periodic tests.

The manufacturer's instruction manual was marked as follows: B&K 2250-L with mic 4950 BE 1774-11 June 2007 From hardware version 2.0.

Adjustment data used to adjust the sound levels indicated in response to the application of a multifrequency sound calibrator to sound levels equivalent to those that would be indicated in response to plane, progressive sound waves were obtained from the manufacturer's instruction manual referred to in this certificate.

The sound level meter calibration check frequency is 1000 Hz, the reference sound pressure level is 94 dB. As this instrument only has a single range, this range is the reference level range.

The environmental conditions in the laboratory at the start of the test were: Static pressure 103.777 kPa \pm 0.013 kPa; air temperature 22.5 °C \pm 0.4 °C; relative humidity 42.7 % \pm 2.1 %.

The initial response of the instrument to application of the associated sound calibrator was 93.9 dB (C). No adjustment of the instrument was required. This indication was obtained from the calibration certificate of the calibrator, 05659/1 and information in the manufacturer's instruction manual specified in this certificate, when the instrument is configured as follows; Transducer: 4950(2745852), Sound Field Correction: Free-field, Windscreen Correction: None. The instrument was calibrated without a windscreen.

With the microphone installed the level of self-generated noise was:

A: 16.1 dB*

* Under-range indicated on instrument display.

With the microphone replaced by an electrical input device with a similar capacitance to the supplied microphone, the levels of self-generated noise were:

A:	11.8 dB*
B:	11.1 dB*
C :	12.5 dB*
Z:	18.1 dB*

* Under-range indicated on instrument display.

The environmental conditions in the laboratory at the end of the test were: Static pressure 103.738 kPa \pm 0.013 kPa; air temperature 23.2 °C \pm 0.4 °C; relative humidity 42.8 % \pm 2.1 %.

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to the units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full except with the prior written approval of the issuing laboratory.

Certificate of Calibration

Issued by University of Salford (Acoustics Calibration Laboratory) UKAS ACCREDITED CALIBRATION LABORATORY NO. 0801

Page 3 of 3

Certificate Number: 05659/2

Date of Issue: 25 March 2022

The sound level meter submitted for testing has successfully completed the class 1 periodic tests of IEC 61672-3:2006, for the environmental conditions under which the tests were performed. As public evidence was available, from an independent testing organization responsible for approving the results of pattern evaluation tests performed in accordance with IEC 61672-2:2003, to demonstrate that the model of sound level meter fully conformed to the requirements in IEC 61672-1:2002, the sound level meter submitted for testing conforms to the class 1 requirements of IEC 61672-1:2002.

The microphone corrections applied as specified in 12.6 of IEC 61672-3:2006 were obtained from a frequency response measured by this Laboratory using the electrostatic actuator method. This response in isolation is not covered by our UKAS accreditation.

Instruments used in the verification procedure were traceable to National Standards. The multi-frequency calibrator method was employed in the acoustical tests of a frequency weighting.

The uncertainty evaluation has been carried out in accordance with UKAS requirements. All measurement results are retained at the acoustic calibration laboratory for at least four years.

-----END OF CERTIFICATE-----

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to the units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full except with the prior written approval of the issuing laboratory.

Brüel & Kja The Calibration Laboratory Skodsborgvej 307, DK-2850 Næ	0	lac-	CAL Reg. nr. 307	٩K
CERTIFICATE	COF CALIBRATION	No: CDK21	06286 Page 1	of 12
CALIBRATION	OF			
Sound Level Meter: Microphone: Preamplifier: Supplied Calibrator:	Brüel & Kjær Type 2250-Ligh Brüel & Kjær Type 4950 Brüel & Kjær Type ZC-0032 None	t No: 3008423 No: 2697054 No: 18175	Id: -	
Software version: Instruction manual:	BZ7222 Version 4.5.2 BE1712-22	Pattern Approval:	PTB1.63-40478500 / 1.63- 4078502	
CUSTOMER				-
	Enfonic Ltd Unit 2A, Century Business F Dublin D11 T0HV Ireland	Park		
CALIBRATION Preconditioning: Environment conditions:	4 hours at $23^{\circ}C \pm 3^{\circ}C$	ntal conditions sections.		
Preconditioning: Environment conditions:	4 hours at 23°C ± 3°C See actual values in Environme .	ntal conditions sections.		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1	4 hours at 23°C ± 3°C See actual values in Environme .	alibrated in accordance with t		1
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1	4 hours at 23°C ± 3°C See actual values in Environmen NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20	alibrated in accordance with t		1
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have	4 hours at 23°C ± 3°C See actual values in Environmen NS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20	alibrated in accordance with t 3 were used perform the perio of Brüel & Kjær Sound Level	odic tests. The accreditation Meter Calibration System 363	
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have	4 hours at 23°C ± 3°C See actual values in Environmen JS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI.	alibrated in accordance with t 3 were used perform the perio of Brüel & Kjær Sound Level	odic tests. The accreditation Meter Calibration System 363	
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi	4 hours at 23°C ± 3°C See actual values in Environment NS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u ration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalua n the standards, calibration method,	alibrated in accordance with t 3 were used perform the perio of Brüel & Kjær Sound Level sing procedure B&K proc 225 uncertainty multiplied by a cov tion has been carried out in ac	odic tests. The accreditation Meter Calibration System 363 50, 4189 (IEC61672:2013) rerage factor $k = 2$ providing a percordance with EA-4/02 from	0 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from	4 hours at 23°C ± 3°C See actual values in Environment JS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance the ration as received. Incertainty is based on the standard up mately 95 %. The uncertainty evaluation in the standards, calibration method, libration.	alibrated in accordance with t 3 were used perform the perio of Brüel & Kjær Sound Level sing procedure B&K proc 225 incertainty multiplied by a cov tion has been carried out in ac effect of environmental condit	odic tests. The accreditation Meter Calibration System 363 50, 4189 (IEC61672:2013) rerage factor $k = 2$ providing a percordance with EA-4/02 from	0 with

Brüel & Kja	er 🛚 🌐 r		
The Calibration Laboratory Skodsborgvej 307, DK-2850 Næ	rum, Denmark		CAL Reg.nr. 307
CERTIFICATE	E OF CALIBRATION	No: CDK21	.03021 Page 1 of 12
CALIBRATION	OF		
Sound Level Meter:	Brüel & Kjær Type 2250	No: 2567756	Id: -
Microphone:	Brüel & Kjær Type 4189	No: 2470482	
Preamplifier:	Brüel & Kjær Type ZC-0032	No: 3418	
Supplied Calibrator:	None		
Software version: Instruction manual:	BZ7222 Version 4.7.5 BE1712-22	Pattern Approval:	PTB1.63-40478500 / 1.63- 4078502
CUSTOMER			
	Enfonic Ltd Unit 2A		
CALIBRATION			
CALIBRATION Preconditioning: Environment conditions: SPECIFICATION	Dublin D11 T0HV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen	ntal conditions sections.	
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of	Dublin D11 T0HV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen	alibrated in accordance with t	
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have	Dublin D11 T0HV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen NS Brücl & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:201 of the international units system SI.	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level	iodic tests. The accreditation
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have	Dublin D11 TOHV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen NS Brücl & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI.	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level	iodic tests. The accreditation
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type	Dublin D11 TOHV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen NS Brücl & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level	iodic tests. The accreditation
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi	Dublin D11 TOHV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen NS Brücl & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u ration as received. ncertainty is based on the standard u mately 95 %. The uncertainty evalue n the standards, calibration method,	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 225 ncertainty multiplied by a cov tion has been carried out in ac	iodic tests. The accreditation 1 Meter Calibration System 3630 with 50, 4189 (IEC61672:2013) verage factor $k = 2$ providing a level
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from	Dublin D11 TOHV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen VS Brücl & Kjær Type 2250 has been c Proceedures from IEC 61672-3:201 of the international units system SI. Proceedures from IEC 61672-3:201 of the international units system SI.	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condi	iodic tests. The accreditation I Meter Calibration System 3630 with 50, 4189 (IEC61672:2013) verage factor $k = 2$ providing a level ccordance with EA-4/02 from
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from from the device under ca	Dublin D11 TOHV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen NS Brücl & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:201 of the international units system SI. been performed with the assistance e 7763 (version 7.3 - DB: 7.30) by u ration as received. ncertainty is based on the standard u mately 95 %. The uncertainty evalua in the standards, calibration method, libration.	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condi	iodic tests. The accreditation I Meter Calibration System 3630 with 50, 4189 (IEC61672:2013) verage factor $k = 2$ providing a level ccordance with EA-4/02 from tions and any short time contribution
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from from the device under ca	Dublin D11 TOHV Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen VS Brücl & Kjær Type 2250 has been c Proceedures from IEC 61672-3:201 of the international units system SI. Proceedures from IEC 61672-3:201 of the international units system SI.	alibrated in accordance with t 3 were used perform the peri of Brüel & Kjær Sound Level sing procedure B&K proc 22: ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condi	iodic tests. The accreditation I Meter Calibration System 3630 with 50, 4189 (IEC61672:2013) verage factor $k = 2$ providing a level ccordance with EA-4/02 from tions and any short time contribution

<image/> Project Sector Sect					
CALIBRATION OF Sund Level Meter: Briel & Kjær Type 2250 No: 3007000 Id: - Microphone: Briel & Kjær Type 27C-0032 No: 23929 Supplied Calibrator: Nore Supplied Calibrator: Briel & Kjær Type 27C-0032 No: 23929 Supplied Calibrator: BE7222 Version 4.5.2 Pattern Approval: PTB1.63-40478500 / 1.63- Testruction manual: BE1712-22 4078502 CUSTOMER CALIBRATION CONDITIONS Preconditioning: A locurs at 23°C ± 3°C Environment conditions: See actual values in Environmental conditions sections. SPECIFICATIONS Preconditioning: A hours at 23°C ± 3°C Environment conditions: See actual values in Environmental conditions sections. SPECIFICATIONS Preconditioning: A hours at 23°C ± 3°C Evironment conditions: See actual values in Environmental conditions sections. SPECIFICATIONS PhoceEDURE Maxwather assistance of Briel & Kjær Sound Level Meter Calibration System 3630 with application software type 7763 (version 7.3 - DB: 7.30) by using procedure B&K proc 2250, 4189 (IECG1672:2013) Colspan= 1	The Calibration Laboratory				DANAK CAL Reg.nr. 307
Sound Level Metter: Brück & Kjær Type 2250 No: 3007000 Id: - Microphone: Brück & Kjær Type 226-0032 No: 3022866 Preampliffer: Brück & Kjær Type ZC-0032 No: 23929 Supplied Calibrator: Nore Preampliffer: Software version: BZ7222 Version 4.5.2 Pattern Approval: PTB1 63-40478500 / 1.63- Instruction manual: BE1712-22 4078502 CUSTOMER CALIBRATION CONDITIONS Presentitioning: X down at 23°C ± 3°C Environment conditions: Secure actual values in Environmental conditions sections. SPECIFICATION CONDITIONS Presentitioning: A down at 23°C ± 3°C Environment conditions: Secure actual values in Environmental conditions sections. SPECIFICATION Presentition for the event by the down at 23°C ± 3°C Environment conditions: Particular Values of Brück A Kjær Type 2250 has been calibration sections. DECIFICATION Presentition: Distributit Value Actual values in E	CERTIFICATE	OF CALIBRATION	No: CDK21	106836	Page 1 of 12
Microphone: Brüel & Kjær Type 4189 No: 3022866 Preampliffer: Bruel & Kjær Type ZC-0032 No: 23929 Supplied Calibrator: Nome Software version: BZ7222 Version 4.5.2 Pattern Approval: PTB1.63-40478500 / 1.63-4078502 Instruction manual: BE1712-22 4078502 CUSTOMER Enfonic Ltd Unit 2A, Century Business Park Dublin D11 T0 HV Ireland Reserved State Presontitioning: 4 bours at 23°C ± 3°C Environment conditioning: 4 bours at 23°C ± 3°C Environment conditioning: 4 bours at 23°C ± 3°C The Sound Level Meter Brüel & Kjær Type 2259 has been calibrated in accordance with the requirements as specified in 18C6162-1:2013 class 1. Proceedures from IEC 61672-3:2013 were used perform the periodic tests. The accreditation assures the traceability of the international units system SI. PROCEDURE The measurements have been performed with the assistance of Brüel & Kjær Sound Level Meter Calibration System 3630 with application software type 7763 (version 7.3 - DB: 7.30) by using procedure B&K proc 2250, 4189 (IEC01672:2013) Date of approximately 65 %, The uncertainty valuation has been carried out in accordance with $F = 2$ providing a level of confidence of approximately 65 %, The uncertainity valuation h	CALIBRATION ()F			
Instruction manual: BE1712-22 4078502 CUSTOMER Enfonic Ltd Unit 2A, Century Business Park Dublin D11 TOHV ireland Preconditioning: a hours at 23°C ± 3°C Environment conditions: See actual values in Environmental conditions sections. SPECIFICATIONS The Sound Level Meter Brüel & Kjær Type 2250 has been calibrated in accordance with the requirements as specified in IEC616/2:12013 class 1. Proceedures from IEC 61672-3:2013 were used perform the periodic tests. The accreditation assures the traceability of the international units system 81. PROCEDURE The Bound Level Meter Brüel & Kjær Type 2250 has been calibrated in accordance with the requirements as specified in IEC616/2:12013 class 1. Proceedures from IEC 61672-3:2013 were used perform the periodic tests. The accreditation assures the traceability of the international units system 81. PROCEDURE The measurements have been performed with the assistance of Brüel & Kjær Sound Level Meter Calibration System 3630 with application software type 7763 (version 7.3 - DB: 7.30) by using procedure B&K proc 2250, 4189 (IEC61672:2013) RESULTS Calibration Mode: Calibration as received. The reported expanded uncertainty is based on the standard uncertainty multiplied by a coverage factor k = 2 providing a level of confidence of approximately 95 %. The uncertainty evaluation has been carried out in accordance with EA-4/02 from elements originating from the standards, calibration method, effect of environmental conditions and any short time contr	Microphone: Preamplifier:	Brüel & Kjær Type 4189 Brüel & Kjær Type ZC-0032	No: 3022866		
Enfonic Ltd Unit 2A, Century Business Park DUIT Dit ToHV Teland Standard St			Pattern Approval:		500 / 1.63-
Enfonic Ltd Unit 2A, Century Business Park DUIT Dit ToHV Teland Standard St	CUSTOMER				
Preconditioning: 4 hours at 23°C ± 3°C Environment conditions: See actual values in Environmental conditions sections. SPECIFICATIONS The Sound Level Meter Brüel & Kjær Type 2250 has been calibrated in accordance with the requirements as specified in IEC6162-1:2013 class 1. Proceedures from IEC 61672-3:2013 were used perform the periodic tests. The accreditation assures the traceability of the international units system SI. PROCEDURE The measurements have been performed with the assistance of Brüel & Kjær Sound Level Meter Calibration System 3630 with application software type 7763 (version 7.3 - DB: 7.30) by using procedure B&K proc 2250, 4189 (IEC61672:2013) RESULTS Calibration Mode: Calibration as received. The reported expanded uncertainty is based on the standard uncertainty multiplied by a coverage factor $k = 2$ providing a level of confidence of approximately 95 %. The uncertainty evaluation has been carried out in accordance with EA-4/02 from from the device under calibration. Date of calibration: 2021-09-14 Mikail Önder Susanne Jorgensen Mikail Önder Susanne Jorgensen Approved Signatory Approved Signatory		Unit 2A, Century Business Dublin D11 T0HV	Park		
IEC6162-1:2013 class 1. Proceedures from IEC 61672-3:2013 were used perform the periodic tests. The accreditation assures the traceability of the international units system SI. PROCEDURE The measurements have been performed with the assistance of Brüel & Kjær Sound Level Meter Calibration System 3630 with application software type 7763 (version 7.3 - DB: 7.30) by using procedure B&K proc 2250, 4189 (IEC61672:2013) RESULTS Calibration Mode: Calibration as received. The reported expanded uncertainty is based on the standard uncertainty multiplied by a coverage factor $k = 2$ providing a level of confidence of approximately 95 %. The uncertainty evaluation has been carried out in accordance with EA-4/02 from elements originating from the standards, calibration method, effect of environmental conditions and any short time contribution from the device under calibration. Date of calibration: 2021-09-14 Date of issue: 2021-09-14 <u>Mikail Önder</u> Susanne Jørgensen Calibration Technician Approved Signatory	Preconditioning: Environment conditions:	4 hours at $23^{\circ}C \pm 3^{\circ}C$ See actual values in Environme	ental conditions sections.		
The measurements have been performed with the assistance of Brüel & Kjær Sound Level Meter Calibration System 3630 with application software type 7763 (version 7.3 - DB: 7.30) by using procedure B&K proc 2250, 4189 (IEC61672:2013) RESULTS Calibration as received. The reported expanded uncertainty is based on the standard uncertainty multiplied by a coverage factor $k = 2$ providing a level of confidence of approximately 95 %. The uncertainty evaluation has been carried out in accordance with EA-4/02 from elements originating from the standards, calibration method, effect of environmental conditions and any short time contribution from the device under calibration. Date of calibration: 2021-09-14 Date of issue: 2021-09-14	IEC6162-1:2013 class 1.	Proceedures from IEC 61672-3:20	13 were used perform the per		
Calibration Mode: Calibration as received. The reported expanded uncertainty is based on the standard uncertainty multiplied by a coverage factor $k = 2$ providing a level of confidence of approximately 95 %. The uncertainty evaluation has been carried out in accordance with EA-4/02 from elements originating from the standards, calibration method, effect of environmental conditions and any short time contribution from the device under calibration. Date of calibration: 2021-09-14 Date of issue: 2021-09-14 $Mikail Önder$ Susanne Jørgensen Calibration Technician Approved Signatory	The measurements have b				
The reported expanded uncertainty is based on the standard uncertainty multiplied by a coverage factor $k = 2$ providing a level of confidence of approximately 95 %. The uncertainty evaluation has been carried out in accordance with EA-4/02 from elements originating from the standards, calibration method, effect of environmental conditions and any short time contribution from the device under calibration. Date of calibration: 2021-09-14 Date of issue: 2021-09-14 Mikail Önder Susanne Jørgensen Calibration Technician Approved Signatory	RESULTS				
M. önderSusanne JørgensenMikail ÖnderSusanne JørgensenCalibration TechnicianApproved Signatory	The reported expanded ur of confidence of approxim elements originating from	ncertainty is based on the standard matching of the standard matching of the standards, calibration method,	ation has been carried out in a	accordance with EA	-4/02 from
Calibration Technician Approved Signatory	Date of calibration	on: 2021-09-14	Date of i	issue: 2021-09-14	
eproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced after written permission.			Sur	U	
	Reproduction of the complete cert	ificate is allowed. Parts of the certificate ma	ay only be reproduced after written pe	ermission.	

Brüel & Kjæ The Calibration Laboratory Skodsborgvej 307, DK-2850 Næn				ANAK Reg.nr. 307
CERTIFICATE	OF CALIBRATION	No: CDK22	203821	Page 1 of 12
CALIBRATION (OF			
Sound Level Meter: Microphone: Preamplifier: Supplied Calibrator:	Brüel & Kjær Type 2250 Brüel & Kjær Type 4189 Brüel & Kjær Type ZC-0032 None	No: 2818081 No: 2785433 No: 24941	Id: - 2820751	
Software version: Instruction manual:	BZ7222 Version 4.7.5 BE1712-22	Pattern Approval:	PTB1.63-4047850 4078502	0 / 1.63-
CUSTOMER				
	Enfonic Ltd Unit 2A, Century Business Dublin D11 T0HV Ireland	Park		
CALIBRATION O Preconditioning: Environment conditions:	CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environme	ental conditions sections.		
SPECIFICATION	C			
The Sound Level Meter H IEC6162-1:2013 class 1.	Brüel & Kjær Type 2250 has been of Proceedures from IEC 61672-3:20 f the international units system SI.			
	been performed with the assistance 7763 (version 7.3 - DB: 7.30) by t			
RESULTS				
of confidence of approxim	ncertainty is based on the standard nately 95 %. The uncertainty evalu the standards, calibration method,	ation has been carried out in a	ccordance with EA-4	'02 from
Date of calibration	on: 2022-02-18	Date of i	ssue: 2022-02-18	
	<i>Onder</i> Mikail Önder ration Technician	Sur	Susanne Jørgensen Approved Signator	iskn_
Reproduction of the complete cert	ificate is allowed. Parts of the certificate ma	ay only be reproduced after written pe	rmission.	

Brüel & Kjæ The Calibration Laboratory Skodsborgvej 307, DK-2850 Nær			CAL Reg.nr. 307
CERTIFICATE	OF CALIBRATION	No: CDK21	08523 Page 1 of 12
CALIBRATION	OF		
Sound Level Meter: Microphone: Preamplifier: Supplied Calibrator:	Brüel & Kjær Type 2250 Brüel & Kjær Type 4231 Brüel & Kjær Type ZC-0032 None	No: 2611593 No: 2730389 No: 12941	Id: -
Software version: Instruction manual:	BZ7222 Version 4.7.5 BE1712-22	Pattern Approval:	PTB1.63-40478500 / 1.63- 4078502
CUSTOMER			
	Enfonic Ltd Unit 2A, Century Business I Dublin D11 T0HV Ireland	Park	
Preconditioning:	4 hours at $23^{\circ}C \pm 3^{\circ}C$		
Environment conditions: SPECIFICATION The Sound Level Meter J	See actual values in Environme.	alibrated in accordance with t	
Environment conditions: SPECIFICATION The Sound Level Meter J IEC6162-1:2013 class 1. assures the traceability o	See actual values in Environme S Brüel & Kjær Type 2250 has been c	alibrated in accordance with t	
Environment conditions: SPECIFICATION The Sound Level Meter I IEC6162-1:2013 class 1. assures the traceability o PROCEDURE The measurements have b	See actual values in Environme. S Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 f the international units system SI.	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level	odic tests. The accreditation Meter Calibration System 3630 with
Environment conditions: SPECIFICATION The Sound Level Meter I IEC6162-1:2013 class 1. assures the traceability o PROCEDURE The measurements have b	See actual values in Environme. S Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:20 f the international units system SI.	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level	odic tests. The accreditation Meter Calibration System 3630 with
Environment conditions: SPECIFICATION The Sound Level Meter II IEC6162-1:2013 class 1. assures the traceability of PROCEDURE The measurements have be application software type RESULTS Calibration Mode: Calibre The reported expanded un of confidence of approxim	See actual values in Environme. S Brüel & Kjær Type 2250 has been of Proceedures from IEC 61672-3:20 f the international units system SI. been performed with the assistance 7763 (version 7.3 - DB: 7.30) by u ration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalua in the standards, calibration method,	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level using procedure B&K proc 225 uncertainty multiplied by a cov ation has been carried out in ac	odic tests. The accreditation Meter Calibration System 3630 with 50, 4189 (IEC61672:2013) verage factor $k = 2$ providing a level
Environment conditions: SPECIFICATION The Sound Level Meter II IEC6162-1:2013 class 1. assures the traceability of PROCEDURE The measurements have be application software type RESULTS Calibration Mode: Calibre The reported expanded un of confidence of approximations from	See actual values in Environme. Sariel & Kjær Type 2250 has been of Proceedures from IEC 61672-3:20 f the international units system SI. peen performed with the assistance 7763 (version 7.3 - DB: 7.30) by u ration as received. neertainty is based on the standard u nately 95 %. The uncertainty evaluate the standards, calibration method, ibration.	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level using procedure B&K proc 22: uncertainty multiplied by a cov ation has been carried out in at effect of environmental condi	odic tests. The accreditation Meter Calibration System 3630 with 50, 4189 (IEC61672:2013) verage factor $k = 2$ providing a level coordance with EA-4/02 from
Environment conditions: SPECIFICATION The Sound Level Meter II IEC6162-1:2013 class 1. assures the traceability of PROCEDURE The measurements have II application software type RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxir elements originating from from the device under calibration Date of calibration	See actual values in Environme. Sariel & Kjær Type 2250 has been of Proceedures from IEC 61672-3:20 f the international units system SI. peen performed with the assistance 7763 (version 7.3 - DB: 7.30) by u ration as received. neertainty is based on the standard u nately 95 %. The uncertainty evaluate the standards, calibration method, ibration.	alibrated in accordance with t 13 were used perform the peri of Brüel & Kjær Sound Level using procedure B&K proc 22: uncertainty multiplied by a cov ation has been carried out in at effect of environmental condi	odic tests. The accreditation Meter Calibration System 3630 with 50, 4189 (IEC61672:2013) verage factor $k = 2$ providing a level ccordance with EA-4/02 from tions and any short time contribution

Brüel & Kja	er 🗉 💮 ĸ	lac	RA 增	DANAK
Skodsborgvej 307, DK-2850 Næ	rum, Denmark	The formation of the second se	white	CAL Reg.nr. 307
CERTIFICATE	E OF CALIBRATION	No: CDK220	08920	Page 1 of 12
CALIBRATION	OF			
Sound Level Meter:	Brüel & Kjær Type 2250	No: 2654662	Id: - 2654662	
Microphone:	Brüel & Kjær Type 4950	No: 2730389		
Preamplifier:	Brüel & Kjær Type ZC-0032	No: 6822		
Supplied Calibrator:	Brüel & Kjær Type 4231	No: 2626210		
Software version: Instruction manual:	BZ7222 Version 4.7.5 BE1712-22	Pattern Approval:	PTB1.63-4047 4078502	8500 / 1.63-
CUSTOMER				
	Enfonic Ltd Unit 2A, Century Business F Dublin	Park		
CALIBRATION				
CALIBRATION Preconditioning: Environment conditions:	Ireland CONDITIONS 4 hours at $23^{\circ}C \pm 3^{\circ}C$	ntal conditions sections.		
Preconditioning:	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environment	ntal conditions sections.		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environment	alibrated in accordance with the		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environment VS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:201	alibrated in accordance with the		
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environment VS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:201	alibrated in accordance with t 3 were used perform the perio of Brüel & Kjær Sound Level	odic tests. The ac	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen VS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:201 of the international units system SI. been performed with the assistance	alibrated in accordance with t 3 were used perform the perio of Brüel & Kjær Sound Level	odic tests. The ac	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environmen VS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:20 of the international units system SI. been performed with the assistance e c 7763 (version 7.3 - DB: 7.30) by u	alibrated in accordance with t 3 were used perform the perio of Brüel & Kjær Sound Level	odic tests. The ac	n System 3630 with
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traccability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environment VS Brüel & Kjær Type 2250 has been c . Proceedures from IEC 61672-3:201 of the international units system SI. been performed with the assistance is e 7763 (version 7.3 - DB; 7.30) by u pration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalues n the standards, calibration method,	alibrated in accordance with th 3 were used perform the period of Brüel & Kjær Sound Level sing procedure B&K proc 225 ncertainty multiplied by a cov tion has been carried out in ac	odic tests. The ac Meter Calibratic 50, 4189 (IEC616 verage factor $k = 1$ ccordance with E	n System 3630 with 72:2013) 2 providing a level A-4/02 from
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traccability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environment VS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:201 of the international units system SI. been performed with the assistance for the international units system SI. been performed with the assistance for e 7763 (version 7.3 - DB: 7.30) by u pration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalua n the standards, calibration method, libration.	alibrated in accordance with th 3 were used perform the period of Brüel & Kjær Sound Level sing procedure B&K proc 225 ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condit	odic tests. The ac Meter Calibratic 50, 4189 (IEC616 verage factor <i>k</i> = 2 ccordance with E	n System 3630 with 72:2013) 2 providing a level A-4/02 from
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter IEC6162-1:2013 class 1 assures the traceability of PROCEDURE The measurements have application software type RESULTS Calibration Mode: Calib The reported expanded u of confidence of approxi elements originating from from the device under calibration	Ireland CONDITIONS 4 hours at 23°C ± 3°C See actual values in Environment VS Brüel & Kjær Type 2250 has been c Proceedures from IEC 61672-3:201 of the international units system SI. been performed with the assistance for the international units system SI. been performed with the assistance for e 7763 (version 7.3 - DB: 7.30) by u pration as received. Incertainty is based on the standard u mately 95 %. The uncertainty evalua n the standards, calibration method, libration.	alibrated in accordance with th 3 were used perform the period of Brüel & Kjær Sound Level sing procedure B&K proc 225 ncertainty multiplied by a cov tion has been carried out in ac effect of environmental condition	odic tests. The ac Meter Calibratic 50, 4189 (IEC616 verage factor $k = 1$ coordance with E tions and any sho	n System 3630 with 72:2013) 2 providing a level A-4/02 from rt time contribution

The Calibration Laboratory Skodsborgvej 307, DK-2850 N	HOTTINGER BRÜEL & KJÆR ærum, Denmark	lac	(hin	DANAK CAL Reg. No. 307 Member of EA MLA
CERTIFICAT	E OF CALIBRATION	No: CDK21	102651	Page 1 of 1
CALIBRATION	OF			
Sound Level Meter:	Brüel & Kjær Type 2250	No: 2690265	Id: -	
Microphone:	Brüel & Kjær Type 4189	No: 2748694		
PreAmplifier: Supplied Calibrator:	Brüel & Kjær Type ZC-0032	No: 15279		
	Brüel & Kjær Type 4231	No: 2389038		
Software version:	BZ7224 Version 4.7.5	Pattern Approval:	PTB1.63-4093	056 / 1.63-
Instruction manual:	BE1712-22		4093058	
CUSTOMER				
	RPS Group Ltd. Mervue G1 Galway Ireland			
CALIBRATION Preconditioning: Environment conditions:	4 hours at $23^{\circ}C \pm 3^{\circ}C$ See actual values in sections.			
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter F 51672-1:2013 class 1. Pro-	4 hours at 23°C ± 3°C See actual values in sections. JS Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we	librated in accordance with th re used to perform the periodi	e requirements as	specified in IEC
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter I 61672-1:2013 class 1. Pro traceability to the interna	4 hours at 23°C ± 3°C See actual values in sections. JS Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we	librated in accordance with the re used to perform the periodi	e requirements a ic tests. The accre	s specified in IEC
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter F 61672-1:2013 class 1. Pro- traceability to the interna PROCEDURE The measurements have b	4 hours at 23°C ± 3°C See actual values in sections. JS Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we	f Brilel & Kizer Sound Level N	Actor Calibaction	editation assures the
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter F 61672-1:2013 class 1. Pro- traceability to the interna PROCEDURE The measurements have b	4 hours at 23°C ± 3°C See actual values in sections. VS Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we tional units system SI.	f Brilel & Kizer Sound Level N	Actor Calibaction	editation assures the
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter H 51672-1:2013 class 1. Pro- raceability to the interna PROCEDURE The measurements have the application software type RESULTS	4 hours at 23°C ± 3°C See actual values in sections. VS Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we tional units system SI. been performed with the assistance of 7763 (version 8.2 - DB: 8.20) by usi	f Brilel & Kizer Sound Level N	Actor Calibaction	editation assures the
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter H 51672-1:2013 class 1. Pri- raceability to the interna PROCEDURE The measurements have H upplication software type RESULTS Calibration Mode: Calibr The reported expanded un f confidence of approxim lements originating from	4 hours at 23°C ± 3°C See actual values in sections. Se actual values in sections. SB Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we tional units system SI. been performed with the assistance of 7763 (version 8.2 - DB: 8.20) by usi ration as received. accertainty is based on the standard un nately 95 %. The uncertainty evaluat the standards, calibration method, e	re used to perform the periodi f Brüel & Kjær Sound Level M ng procedure B&K proc 2250 certainty multiplied by a cove	Meter Calibration (1), 4189 (IEC 616) erage factor $k = 2$	System 3630 with 72:2013).
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter F 51672-1:2013 class 1. Pre traceability to the interna PROCEDURE The measurements have b upplication software type RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim	4 hours at 23°C ± 3°C See actual values in sections. See actual values in sections. SB Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we tional units system SI. been performed with the assistance of 7763 (version 8.2 - DB: 8.20) by using the standard section of the standard units has been been been been been been been bee	re used to perform the periodi f Brüel & Kjær Sound Level M ng procedure B&K proc 2250 certainty multiplied by a cove ion has been carried out in acc ffect of environmental conditi	Meter Calibration (1), 4189 (IEC 616) erage factor $k = 2$	System 3630 with 72:2013).
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter I 61672-1:2013 class 1. Pro- traceability to the interna PROCEDURE The measurements have B upplication software type RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim lements originating from trom the device under cali	4 hours at 23°C ± 3°C See actual values in sections. See actual values in sections. SB Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we tional units system SI. been performed with the assistance of 7763 (version 8.2 - DB: 8.20) by using the standard section of the standard units has been been been been been been been bee	re used to perform the periodi f Brüel & Kjær Sound Level M ng procedure B&K proc 2250 certainty multiplied by a cove ion has been carried out in acc ffect of environmental conditi	Meter Calibration (4189 (IEC 616) (4189 factor $k = 2$) (and any shore)	System 3630 with 72:2013).
Preconditioning: Environment conditions: SPECIFICATION The Sound Level Meter F 51672-1:2013 class 1. Pro traceability to the interna PROCEDURE The measurements have for upplication software type RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim fements originating from rom the device under cali	4 hours at 23°C ± 3°C See actual values in sections. See actual values in sections. SB Brüel & Kjær Type 2250 has been ca ocedures from IEC 61672-3:2013 we tional units system SI. been performed with the assistance of 7763 (version 8.2 - DB: 8.20) by using the standard section of the standard units has been been been been been been been bee	re used to perform the periodi f Brüel & Kjær Sound Level M ng procedure B&K proc 2250 certainty multiplied by a cove ion has been carried out in acc ffect of environmental conditi	Meter Calibration (4189 (IEC 616) (4189 factor $k = 2$) (and any shore)	System 3630 with 72:2013).

	HOTTINGER BRUEL & KJÆR	ALL	
The Calibration Laboratory		ilac-MRA	
Skodsborgvej 307, DK-2850 Nærum, Denmark			CAL Reg.No. 307 Member of EA MLA
		The Andrews	
CERTIFICATE OF CALIBRATION		No: CDK2102594	Page 1 of 4
CALIBRATION	OF		
Supplied Calibrator:	Brüel & Kjær Type 4231	No: 2389038 Id: -	
12 Inch adaptor:	Brüel & Kjær Type UC-0210		
Pattern Approval:	PTB-1.61-4057176		
CUSTOMER			
	RPS Group Ltd.		
	Mervue G1 Galway		
	Ireland		
Preconditioning:	4 hours at $23^{\circ}C \pm 3^{\circ}C$		
Preconditioning: Environment conditions:		.H. Temperature: 22.9 °C.	
	Pressure: 100.07 kPa. Humidity: 41 % R	H. Temperature: 22.9 °C.	
Environment conditions: SPECIFICATION The Supplied Calibrator E	Pressure: 100.07 kPa. Humidity: 41 % R	d in accordance with the requirement	is specified in SI.
Environment conditions: SPECIFICATION The Supplied Calibrator E	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kiær Type 4231 has been calibrate	d in accordance with the requirement	is specified in SI.
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kiær Type 4231 has been calibrate	d in accordance with the requirements a ability to the international units system	SI.
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kjær Type 4231 has been calibrate. Class 1. The accreditation assures the trace	d in accordance with the requirements a ability to the international units system	SI.
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b software Type 7794 (versi RESULTS Calibration Mode: Calibr	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kjær Type 4231 has been calibrate. Class 1. The accreditation assures the trace been performed with the assistance of Brüel ion 2.5) by using procedure P_4231_D07.	d in accordance with the requirements a ability to the international units system & Kjær acoustic calibrator calibration	SI.
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b software Type 7794 (version RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kjær Type 4231 has been calibrate Class 1. The accreditation assures the trace been performed with the assistance of Brüel ion 2.5) by using procedure P_4231_D07. ation after repair/adjustment. certainty is based on the standard uncertain tately 95 %. The uncertainty evaluation has the standards, calibration method, effect of	d in accordance with the requirements a ability to the international units system & Kjær acoustic calibrator calibration ty multiplied by a coverage factor $k = 2$	SI. application
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b software Type 7794 (versi RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim elements originating from	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kjær Type 4231 has been calibrate. Class 1. The accreditation assures the trace been performed with the assistance of Brüel ion 2.5) by using procedure P_4231_D07. ation after repair/adjustment. certainty is based on the standard uncertain nately 95 %. The uncertainty evaluation has the standards, calibration method, effect of bration.	d in accordance with the requirements a ability to the international units system & Kjær acoustic calibrator calibration ty multiplied by a coverage factor $k = 2$	SI. application
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b software Type 7794 (versi RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim elements originating from from the device under cali Date of calibratio	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kjær Type 4231 has been calibrate. Class 1. The accreditation assures the trace been performed with the assistance of Brüel ion 2.5) by using procedure P_4231_D07. ation after repair/adjustment. Interly 95 %. The uncertainty evaluation has the standards, calibration method, effect of bration. n: 2021-04-09	d in accordance with the requirements a ability to the international units system & Kjær acoustic calibrator calibration ty multiplied by a coverage factor $k = 2$ been carried out in accordance with E, environmental conditions and any sho	SI. application
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b software Type 7794 (versi RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim tements originating from rom the device under cali Date of calibratio	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kjær Type 4231 has been calibrate. Class 1. The accreditation assures the trace been performed with the assistance of Brüel ion 2.5) by using procedure P_4231_D07. ation after repair/adjustment. certainty is based on the standard uncertain nately 95 %. The uncertainty evaluation has the standards, calibration method, effect of bration.	d in accordance with the requirements a ability to the international units system & Kjær acoustic calibrator calibration ty multiplied by a coverage factor $k = 2$ been carried out in accordance with E, environmental conditions and any sho Date of issue: 2021-04-09	SI. application
Environment conditions: SPECIFICATION The Supplied Calibrator E IEC60942:2003 Annex B PROCEDURE The measurements have b software Type 7794 (versi RESULTS Calibration Mode: Calibr The reported expanded un of confidence of approxim elements originating from rom the device under cali Date of calibratio	Pressure: 100.07 kPa. Humidity: 41 % R S Brüel & Kjær Type 4231 has been calibrate Class 1. The accreditation assures the trace been performed with the assistance of Brüel ion 2.5) by using procedure P_4231_D07. ation after repair/adjustment. certainty is based on the standard uncertain tately 95 %. The uncertainty evaluation has the standards, calibration method, effect of bration. n: 2021-04-09 HAUSER	d in accordance with the requirements a ability to the international units system & Kjær acoustic calibrator calibration ty multiplied by a coverage factor $k = 2$ been carried out in accordance with E, environmental conditions and any sho	SI. application 2 providing a level A-4/02 from rt time contribution

C1 - Public