

002		ADDED DIMENSIONS & SCALES								
001	21/08/23	SHEET SIZE UPDATED TO A2	NB	NB	RD	RD				
000	11/07/23	FIRST ISSUE	NB	NB	RD	RD				
Rev.	Date	Revision Description	Dm.	Prod.	Ver.	App.				
Purpose of issue - Preliminary unless indicated										
Client Approval Planning X Tender Construction As-built										



Engineering and Major Projects, One Dublin Airport Central, Dublin Airport, Cloghran, Co. Dublin, K67 XF72, Ireland. Tel: +353 (0)1 703 8000 Web: www.esb.ie ORIEL WINDFARM LIMITED ORIEL WIND FARM PROJECT Production Unit
Civil, Environmental and Renewable Engineering COMMUNICATIONS CHAMBER

GENERAL ARRANGEMENT

Drawing Number

\bigcup	COPYRIGHT ESB All rights reserved. No part of this work may be modified, reproduced or copied in any form or by any means - graphic, electronic or mechanical, including photocopying, recording, taping or used for any purpose other than its designated purpose, without the written permission of ESB.										
\bigcap	DRAWN	PRODUCED	VERIFIED	APPROVED		APPROVAL DAT					
	N.BELL	N.BELL	R.DOYLE	M.HOGAN		1/AS/10/11/01					
	-1	CLIENT REF		No. OF SHTS	SIZE	SCALE					
	<u> </u>	TC	1/1	A2	AS STATE						

NOTES:

AUTHORITY.

1. ALL DIMENSIONS IN MILLIMETRES.

2. REINSTATEMENT TO COMPLY WITH REQUIREMENTS OF THE RELEVANT LOCAL

4. ALL MATERIALS AND WORKMANSHIP TO

SPECIFICATION FOR ROADWORKS, MAY 2005

5. REINFORCED CONCRETE TO BE MINIMUM GRADE C32/40 TO I.S.EN 206. SULPHATE

RESISTING CEMENT TO BE USED WHERE AGGRESSIVE SOIL CONDITIONS APPLY,

6. CARRIAGEWAY COVERS AND FRAMES TO

7. ALL COVERS SHALL HAVE 'ESB' LOGO INCORPORATED IN THEM TO THE APPROVAL

GALVANISED TO B.S. 729 AND POSITIONED AS SHOWN ON ANY CHAMBER DEEPER

THAN 700mm ON THE END REMOTE FROM

ENGINEERING. BEDS AND JOINTS TO BE

BE IN ACCORDANCE WITH THE NRA

REFER TO TABLE 6.1 OF B.S. 8110.

8. STEP IRONS TO BE HOT DIPPED

3. END DUCTS TO BE IN LINE.

& SUBSEQUENT REVISIONS.

BE TO B.S. EN 124.

OF THE ENGINEER.

ANY SIDE ENTRY DUCT.

CLASS 1 MORTAR.

9. BRICKWORK TO BE CLASS B

PE605-D027-071-002-002