



- NOTE:
1. TEMPORARY POST & WIRE FENCE TO COMPLY WITH THE DRAWING C0/SCD3004.
  2. THE PROPOSED ENABLING WORKS AREA LAYOUT IS INDICATIVE. LAND ACCESS AGREEMENTS SHOULD BE REFERRED TO FOR EXACT LOCATION OF THE ENABLING WORKS AREA AT EACH PASSING BAY.
  3. IT IS THE CONTRACTOR'S SCOPE TO DETERMINE THE LEVELS OF CUT AND FILL AND THE SIZE AND LEVELS OF TEMPORARY DRAIN ETC. THE SIZE OF THE PASSING BAY WILL VARY DEPENDING ON EACH LOCATION AND THE VOLUME OF TOPSOIL.
  4. PASSING BAY MAKE-UP SHALL CONSIST OF MINIMUM 250 mm THICK LAYER OF COMPACTED CL 804 GRANULAR MATERIAL LAID ON 6F12 GRANULAR MATERIAL ON APPROVED GEOTEXTILE LINER. EXACT THICKNESS LAYER TO BE DETERMINED BY CONTRACTOR AT EACH LOCATION BASED ON THE CONTRACTOR'S TEMPORARY WORKS DESIGN. SURFACE TO BE LAID TO PROMOTE DRAINAGE AWAY FROM THE PUBLIC ROAD AND THE PASSING BAY.
  5. TRAFFIC MANAGEMENT CONSISTING OF TRAFFIC LIGHTS OR STOP/GO SYSTEM SHALL BE PROVIDED AT EACH LOCATION. THE SURFACE SHALL BE MAINTAINED IN A SAFE TRAFFICABLE CONDITIONS AS PER THE NON-TECHNICAL SPECIFICATION.
  6. THE ENABLING WORKS AREA SHALL BE RESTORATED TO MATCH THE ORIGINAL GROUND LEVELS AND PROFILES. FENCE LINES, DRAINAGE AND PLANTING WILL BE RESTORATED TO MATCH ORIGINAL OR AS PER THE RELEVANT SPECIFICATION.
  7. LOCATION OF JOINT BAY, LINK BOX AND C2 COMMUNICATIONS CHAMBER SHOWN INDICATIVELY.
  8. THE CABLE INSTALLATION METHOD SHOWN IS INDICATIVE ONLY TO ILLUSTRATE THE MAXIMUM WORKING AREA AVAILABLE. ALTERNATIVE CABLE INSTALLATION METHODS ARE AVAILABLE AND THE SELECTED METHOD SHALL BE SITE SPECIFIC.



PLAN VIEW OF JOINT BAY & PASSING BAY  
SCALE: 1 : 100



REV	DATE	REVISION DESCRIPTION	DRN	PRD	VER1	VER2	APP
000	Mar 20	ISSUED FOR PLANNING					

Copyright © ESB  
All rights reserved. No part of this work may be modified, reproduced or copied in any form or by any means - graphic, electronic or mechanical, including photocopying, recording, taping or used for any purpose other than its designated purpose, without the written permission of ESB.

PURPOSE OF ISSUE - PRELIMINARY UNLESS INDICATED  
 CLIENT APPROVAL  PLANNING  TENDER  CONSTRUCTION  AS-BUILT

Client: Oriel Windfarm Ltd

Project: Oriel Wind Farm Project

Contract:

Drawing Title: Temporary Joint Bay & Passing Bay General Arrangement

Production Unit: Civil & Environmental Engineering

Engineering and Major Projects,  
One Dublin Airport Central, Dublin Airport,  
Cloghran, Co. Dublin, K67 XF72, Ireland.  
Tel: +353 (0)1 703 8000 Web: www.esb.ie  
Engineering and Major Projects is a division of ESB

DRAWN	PRODUCED	VERIFIED 1	APPROVED	APPROVAL DATE
A. Gillespie	P.O'Neill	P. Friend Pereira	M. Amet	15/04/2020

CLIENT REF	No. of Shs	SIZE	SCALE
1		A1	1 : 100

DRAWING NUMBER: PE605-D027-015-001-000